



FONTANA FIRE PROTECTION DISTRICT FIRE PREVENTION



SUBMITTAL CHECKLIST NFPA 24 2013 EDITION - PRIVATE UNDERGROUND WATERLINE & HYDRANT SYSTEM

GENERAL:	CONTR	FIRE
1) A minimum of three sets of drawings		
2) Completed application		
3) Payment		
DRAWINGS MUST SHOW THE FOLLOWING TO BE ACCEPTED:	CONTR	FIRE
4) Name of project, building sq/ft and construction type		
5) Location, including street address and city		
6) Name, address, phone number and license number of contractor		
7) Scaled or fully dimensional drawing		
8) Plan done by Professional Engineer		
9) Point of compass		
10) Equipment symbol legend per NFPA 720		
11) Pipe size and placement to hydrant(s)		
12) Size and location of all water supplies		
14) Size, length, location and material of fire service mains		
15) Point of connection to city main		
16) Number of risers		
17) Sizes, types and locations of control valves		
18) Depth of buried pipe and provisions of tracer wire		
19) Method of restraint for fire mains include manufacturer cut sheets		
20) Number, size and location of hydrants, including size and number of outlets		
21) If used, all thrust blocks shall be calculated and constructed in accordance with NFPA 24		
22) Size, location and piping arrangement of FDC, PIV and/or OS & Y		
ADDITIONAL INFORMATION REQUIRED:	CONTR	FIRE
23) Flow report dated less than a year		
24) Minimum two sets of hydraulic calculations		
25) Conditions of Approval		

NOTES: